

Permit Inspections

City of Denton

Permit Number: 0307-0093

Description: **DENTON AQUATIC CENTER**

Applied: **7/7/2003**

Approved: **6/26/2004**

Site Address: **2400 LONG RD**

Issued: **6/26/2004**

Finaled: **6/27/2004**

City, State Zip Code: **Denton, TX 76201**

Status: **ACTIVE**

Applicant: **POOL AT AQUATIC CENTER**

Parent Permit: **0307-0092**

Owner: **DENTON, CITY OF**

Parent Project:

Contractor: **Charter Builders, LTD**

Details:

WATER 665-002-COMM-8125-662D-I0101

WASTEWATER 677-002-COMM-8125-662D-I0101

POOL PERMIT MAILED INTER-OFFICE 06-24-05

(3/14/2008 15:59 lp)

PERMIT MAILED INTEROFFICE 03-14-08

DENTON AQUATIC CENTER

LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
	5/29/2003	5/29/2003	CH - POOL	JOSH TRAVIS	FAILED	SEE NOTES
Notes: LASS A POOLS - ON COMPETITION POOL AT SHALLOW END ADD INTERNATIONAL SYMBOL NEXT TO "NO DIVING" OUTSIDE BY SLIDES ADD INTERNATIONAL SYMBOL						
	6/18/2003	6/18/2003	CH - POOL	LAURIE PEARSON	APPROVED	SEE NOTES
Notes: POOLS OK TO OPEN; SANDWICHES WILL BE MADE AT THE MARTIN LUTHER KING, JR. CENTER UNTIL THE CONCESSION TRAILER IS BROUGHT IN PERMANENTLY; IN ONE STORE ROOM OUT BY RESTROOMS THEY HAVE A 3 DR. UPRIGHT COMMERCIAL REFRIGERATOR AND A 2 DR. UPRIGHT COMMERCIAL FREEZER; EMPLOYEES TO HAVE THERMOMETERS (0-220 DEGREES) TO TAKE TEMPERATURES OF FOODS TO ENSURE PROPER HOLDING TEMPERATURES						
	6/20/2003	6/20/2003	CH - POOL	JOSH TRAVIS	APPROVED	SEE NOTES
Notes: TORE ALL SNACKS (IN BOXES) 6" OFF FLOOR' COLD SANDWICHES MADE AT MLK CENTER ARE OK TO SELL BUT DO NOT SELL HOT DOGS FROM THIS FACILITY BECAUSE THERE IS NO HANDWASHING SINK OR WAREWASHING SINK AT THIS TIME. ANY PRE-PACKAGED SNACKS ARE OK TO SELL AND BOTTLED DRINKS, BUT NO OPEN FOODS EXCEPT FOR SANDWICHES PRE-MADE AND PRE-WRAPPED AT MLK. CLEAN "STUFF" OFF TOP OF ICE MACHINE.						
	7/11/2003	7/11/2003	CH - POOL	LAURIE PEARSON	APPROVED	SEE NOTES
Notes: UTDOOR SLIDE POOL - CHLORINE 3.0 PH 7.2						
	7/11/2003	7/11/2003	CH - POOL	LAURIE PEARSON	APPROVED	SEE NOTES
Notes: AZY RIVER - CHLORINE 3.0 PH 7.6						

Permit Inspections

City of Denton

	7/11/2003	7/11/2003	CH - POOL	JOSH TRAVIS	APPROVED	SEE NOTES
Notes: INSIDE - INSTRUCTION POOL CHLORINE 5.0 PH 7.4						
	7/11/2003	7/11/2003	CH - POOL	LAURIE PEARSON	APPROVED	SEE NOTES
Notes: HILDREN'S SPLASHER POOL - CHLORINE 2.0 PH 7.0						
	7/11/2003	7/11/2003	CH - POOL	JOSH TRAVIS	APPROVED	SEE NOTES
Notes: OMPETITION POOL: CHLORINE 1.5 PH 7.2						
	8/13/2003	8/13/2003	CH - POOL	LAURIE PEARSON	APPROVED	SEE NOTES
Notes: HILDREN'S SPLASH POOL: CHLORINE - 0; PH 7.4 (8/13/2003 13:38 lp)POOL MANAGER CAROLYN CORRECTED PROBLEM WHILE WE WERE THERE - APPARENTLY WHEN THEY TURNED SOME OF THE EQUIPMENT OFF LAST NIGHT THE CHLORINE PUMP ALSO GOT TURNED OFF TO THIS ONE POOL...						
	8/13/2003	8/13/2003	CH - POOL	LAURIE PEARSON	APPROVED	SEE NOTES
Notes: LIDE POOL INDOORS; CHLORINE: 2.0; PH 7.6						
	8/13/2003	8/13/2003	CH - POOL	LAURIE PEARSON	APPROVED	SEE NOTES
Notes: LIDE POOL OUTSIDE: CHLORINE 3.0; PH 7.0						
	8/13/2003	8/13/2003	CH - POOL	LAURIE PEARSON	APPROVED	SEE NOTES
Notes: AZY RIVER- CHLORINE: 3.0 PH 7.2						
	8/13/2003	8/13/2003	CH - POOL	LAURIE PEARSON	APPROVED	SEE NOTES
Notes: OMPETITION POOL : CHLORINE 3.0; PH 7.2						
	6/21/2004	6/21/2004	CH - POOL	JOSH TRAVIS	APPROVED	instuctional
Notes:						
	6/21/2004	6/21/2004	CH - POOL	JOSH TRAVIS	APPROVED	outdoor catch pool
Notes:						
	6/21/2004	6/21/2004	CH - POOL	JOSH TRAVIS	APPROVED	children's outside
Notes:						
	6/21/2004	6/21/2004	CH - POOL	JOSH TRAVIS	APPROVED	competion pool
Notes:						

Permit Inspections

City of Denton

	6/21/2004	6/21/2004	CH - POOL	JOSH TRAVIS	APPROVED	lazy river
Notes:						
	6/22/2005	6/22/2005	CH - POOL	LAURIE PEARSON	APPROVED	COMPETITION POOL
Notes:						
	6/22/2005	6/22/2005	CH - POOL	LAURIE PEARSON	APPROVED	INDOOR SLIDE POOL
Notes:						
	6/22/2005	6/22/2005	CH - POOL	LAURIE PEARSON	APPROVED	RIVER
Notes:						
	6/22/2005	6/22/2005	CH - POOL	LAURIE PEARSON	APPROVED	OUTDOOR SLIDE
Notes:						
	6/22/2005	6/22/2005	CH - POOL	LAURIE PEARSON	APPROVED	BABY POOL
Notes:						
	8/3/2005	8/3/2005	CH - POOL	LAURIE PEARSON	APPROVED	BABY POOL
Notes:						
	8/3/2005	8/3/2005	CH - POOL	LAURIE PEARSON	APPROVED	LAZY RIVER
Notes:						
	8/3/2005	8/3/2005	CH - POOL	LAURIE PEARSON	APPROVED	OUTDOOR SLIDE
Notes:						
	8/3/2005	8/3/2005	CH - POOL	LAURIE PEARSON	APPROVED	INDOOR SLIDE
Notes:						
	8/3/2005	8/3/2005	CH - POOL	LAURIE PEARSON	APPROVED	COMPETITION POOL
Notes:						
	2/23/2006	2/23/2006	CH - COMPLAINT	LAURIE PEARSON	<none>	see notes
Notes:						
WE RECEIVED A COMPLAINT THAT A PERSON AND HIS GRANDCHILDREN SWAM IN THE POOL ON THE 11TH AND HAD SKIN IRRITATION AFTERWARDS						

Permit Inspections

City of Denton

	2/24/2006	2/24/2006	CH - POOL	Laurie Pearson	APPROVED	SEE NOTES
Notes: WE INSPECTED BOTH INDOOR POOLS - THE COMPETITION POOL AND THE LIESURE POOL....BOTH POOLS HAD CRYSTAL CLEAR WATER AND CHLORINE READINGS OF 2.0 AND 3.0 PPM WHICH IS ABOVE STATE REQUIREMENTS. PH WAS IN BALANCE ON BOTH POOLS. LOG READINGS FROM THE POOL LIFEGUARDS FOR THAT DAY ALSO SHOWED CORRECT POOL CHEMISTRY						
	8/16/2006	8/16/2006	CH - POOL	JACKIE WELDON	APPROVED	INSIDE POOL
Notes: THE INSIDE POOL WITH SLIDE WAS GOOD. THE CHLORINE WAS 2.0 AND THE PH WAS 7.2.						
	8/16/2006	8/16/2006	CH - POOL	Laurie Pearson	APPROVED	COMPETITION
Notes: LAP POOL WAS GOOD. CHLORINE 5.0 - PH 7.2.						
	8/16/2006	8/16/2006	CH - POOL	JACKIE WELDON	APPROVED	SLIDE
Notes: SLIDE POOL HAS ALOT OF PIVOTS ON BOTTOM OF POOL. NEEDS TO BE RESURFACE ON THE BOTTOM. THE PH IN THIS POOL WAS LOW. (7.0)						
	8/16/2006	8/16/2006	CH - POOL	JACKIE WELDON	APPROVED	BABY POOL
Notes: BABY POOL LOOKED GOOD. THE CHLORINE LEVEL WAS 5.0 AND PH LEVEL 7.2.						
	8/16/2006	8/16/2006	CH - POOL	Laurie Pearson	APPROVED	LAZY RIVER
Notes: LAZY RIVER POOL HAD NO CHLORINE. BROUGHT IT TO TOM'S ATTENTION AND HE CORRECTED IT. POOL NOT USED DURING THE WEEK ANYMORE SINCE SCHOOL STARTED. THE LAZY RIVER HAD A LOT OF PIVOTS AND CRACKS ON BOTTOM OR POOL. WILL BE REDONE FOR NEXT YEAR.						
	9/18/2006	9/18/2006	CH - COMPLAINT	Laurie Pearson	<none>	SEE NOTES
Notes: WE RECEIVED A COMPLAINT THAT ROACHES WERE SEEN IN THE LADIES LOCKER ROOM; THAT THERE WAS A GENERAL LACK OF CLEANLINESS IN THE DRESSING ROOMS AND THE POOLS; THAT THERE HAD BEEN VOMIT IN A CORNER BY THE COMPETITION POOL THAT DID NOT GET CLEANED UP FOR MANY WEEKS; THAT MATS WERE PUT INTO THE POOLS TO BE WASHED; THAT THERE WAS A URINE SMELL BY THE SHOWERS AND MOLD SEEN IN SHOWERS						
	9/19/2006	9/19/2006	CH - POOL	Laurie Pearson	<none>	SEE NOTES
Notes: JACKIE KILZ AND I MET WITH TOM KLIMKO THIS MORNING AND MADE AN INSPECTION OF THE ENTIRE INDOOR POOL AREA AND THEN WE LOOKED IN THE LADIES DRESSING ROOM AREAS AND LOCKER ROOMS. WE DID NOT SEE ANY UNSANITARY CONDITIONS IN THE LOCKER ROOMS OR DRESSING ROOMS OR SHOWER AREAS OR BATHROOMS. WE DID SEE ROACHES IN THE DOORWAY LEADING OUT TO THE POOL AND MR. KLIMKO HAS CALLED DENTON COUNTY PEST CONTROL TO HAVE THEM COME OUT TOMORROW AND SPRAY. I RECOMMENDED THEY HAVE THE BUILDING SPRAYED 2 TIMES A MONTH TO GET THE INFESTATION UNDER CONTROL						

Permit Inspections

City of Denton

	5/23/2007	5/23/2007	CH - POOL	LAURIE PEARSON	APPROVED	LAP POOL
Notes:						
	5/23/2007	5/23/2007	CH - POOL	LAURIE PEARSON	APPROVED	COMPETITION POOL
Notes:						
	5/23/2007	5/23/2007	CH - POOL	JACKIE WELDON	APPROVED	BABY POOL
Notes:						
	5/23/2007	5/23/2007	CH - POOL	JACKIE WELDON	APPROVED	LAZY RIVER
Notes:						
	5/23/2007	5/23/2007	CH - POOL	JACKIE WELDON	APPROVED	SLIDE POOL OUTDOORS
Notes:						
	8/16/2007	8/16/2007	CH - POOL	LAURIE PEARSON	APPROVED	COMPETITION POOL
Notes:						
	8/16/2007	8/16/2007	CH - POOL	LAURIE PEARSON	APPROVED	INDOOR POOL
Notes:						
	8/16/2007	8/16/2007	CH - POOL	LAURIE PEARSON	FAILED	CATCH POOL/ NOTE
Notes:						
NO CHLORINE ; PH TOO LOW NOTE: ALL THE OUTDOOR POOLS ARE CLOSED NOW FOR THE SEASON DURING THE WEEK - WILL BALANCE CHEMICALS AND HAVE THEM READY FOR THE WEEKEND POOLS CLOSE AFTER LABOR DAY						
	8/16/2007	8/16/2007	CH - POOL	LAURIE PEARSON	FAILED	BABY POOL/ NOTE
Notes:						
NO CHLORINE IN BABY POOL - OUTDOOR POOLS CLOSED NOW DURING WEEK - WILL BALANCE CHEMICALS BEFORE THE WEEKEND POOLS CLOSE AFTER LABOR DAY						
	8/16/2007	8/16/2007	CH - POOL	LAURIE PEARSON	FAILED	LAZY RIVER/ NOTE
Notes:						
OUTDOOR POOLS CLOSED DURING WEEK - WILL BALANCE CHEMICALS BEFORE WEEKEND POOLS CLOSE AFTER LABOR DAY WEEKEND						

Permit Inspections

City of Denton

	5/16/2008	5/16/2008	CH - POOL	JACKIE WELDON	FAILED	BABY POOL
Notes: NO CHLORINE IN BABY POOL AT THIS TIME PARK HOPES TO OPEN POOLS TOMORROW						
	5/16/2008	5/16/2008	CH - POOL	JACKIE WELDON	APPROVED	LAZY RIVER
Notes:						
	5/16/2008	5/16/2008	CH - POOL	JACKIE WELDON	APPROVED	CATCH BASIN POOL
Notes:						
	5/16/2008	5/16/2008	CH - POOL	Laurie Pearson	APPROVED	LEISURE POOL
Notes:						
	5/16/2008	5/16/2008	CH - POOL	Laurie Pearson	APPROVED	COMPETITION POOL
Notes:						
	8/15/2008	8/15/2008	CH - POOL	JACKIE WELDON	APPROVED	COMPETITION
Notes: CHLORINE: 5 PH: 7.4 LIFE GUARD ON DUTY						
	8/15/2008	8/15/2008	CH - POOL	JACKIE WELDON	APPROVED	LEISURE
Notes: CHLORINE: 2 PH: 7.4						
	8/15/2008	8/15/2008	CH - POOL	JACKIE WELDON	APPROVED	BABY
Notes: CHLORINE: 5 PH: 7.4						
	8/15/2008	8/15/2008	CH - POOL	JACKIE WELDON	APPROVED	WATER SLIDE
Notes: CHLORINE: 5.0 PH: 7.2 SINCE IT HAD BEEN RAINING ALL DAY THE POOLS HAD SOME DIRT IN THEM.						
	8/15/2008	8/15/2008	CH - POOL	JACKIE WELDON	APPROVED	LAZY
Notes: CHLORINE: 6.0 PH: 7.4						

Permit Inspections

City of Denton

	5/15/2009	5/15/2009	CH - POOL	Laurie Pearson	APPROVED	BABY POOL/NOTES
Notes: DIRT IN BABY POOL (NOTE - POOL NOT OPEN FOR SEASON YET) CHLORINE HIGH 6.5 AND PH TOO HIGH 8.0						
	5/15/2009	5/15/2009	CH - POOL	Laurie Pearson	APPROVED	EXERCISE POOL INDOOR
Notes:						
	5/15/2009	5/15/2009	CH - POOL	Laurie Pearson	APPROVED	COMPETITION POOL
Notes:						
	5/15/2009	5/15/2009	CH - POOL	Jackie Weldon	APPROVED	LAZY RIVER
Notes:						
	5/15/2009	5/15/2009	CH - POOL	Jackie Weldon	APPROVED	CATCH BASIN/NOTE
Notes: NO CHLORINE IN POOL AT BASE OF SLIDES OUTDOOR						
	8/14/2009	8/14/2009	CH - POOL	Laurie Pearson	APPROVED	competition pool
Notes: chlorine 3.0; ph 7.2						
	8/14/2009	8/14/2009	CH - POOL	Laurie Pearson	APPROVED	indoor slide pool
Notes: chlorine 3.0; ph 7.2						
	8/14/2009	8/14/2009	CH - POOL	Laurie Pearson	APPROVED	catch pool
Notes: chlorine 2.0 ; ph 7.2						
	8/14/2009	8/14/2009	CH - POOL	Laurie Pearson	APPROVED	river
Notes: chlorine 4.0 ; ph 7.4; NOTE: some areas of river pool bottom may need patching before next summer						
	8/14/2009	8/14/2009	CH - POOL	Laurie Pearson	APPROVED	baby pool
Notes: chlorine 3.0; ph 7.2						
	5/10/2010	5/10/2010	CH - POOL	Jackie Weldon	APPROVED	LAP POOL/NOTES
Notes: CHLORINE: 5.0 PPM PH: 7.0 LOOSE HAND RAILS, PLEASE FIX.						

Permit Inspections

City of Denton

	5/10/2010	5/10/2010	CH - POOL	JACKIE WELDON	APPROVED	RECREATION POOL
Notes: CHLORINE: 7.0 PH: 7.4						
	5/13/2010	5/13/2010	CH - POOL	ANDRIA MCAULEY	APPROVED	Baby pool outside
Notes: No violations Chl= 1.0ppm pH= 7.5						
	5/13/2010	5/13/2010	CH - POOL	ANDRIA MCAULEY	APPROVED	Lazy river outside
Notes: no violations Chl= 1ppm pH= 7.8						
	5/13/2010	5/13/2010	CH - POOL	ANDRIA MCAULEY	APPROVED	Slide pool
Notes: no violations Chl= 4.5ppm pH= 7.8						
	8/10/2010	8/10/2010	CH - POOL	BILL TOMLIN	APPROVED	RIVER POOL
Notes: CHLORINE 5.0; PH 7.2						
	8/11/2010	8/11/2010	CH - POOL	BILL TOMLIN	APPROVED	SPLASH POOL
Notes: CHLORINE 3.0; PH 7.2						
	8/11/2010	8/11/2010	CH - POOL	BILL TOMLIN	APPROVED	KIDS POOL
Notes: CHLORINE 3.0; PH 7.4						
	8/11/2010	8/11/2010	CH - POOL	GARY HUNDLEY	APPROVED	INSTRUCTION POOL INSIDE
Notes: CHLORINE 5.0; PH 7.0						
	8/11/2010	8/11/2010	CH - POOL	GARY HUNDLEY	APPROVED	COMPETITION POOL
Notes: chlorine 6.0; ph 7.0						

Permit Inspections

City of Denton

	8/10/2011	8/10/2011	CH - POOL	LAURIE PEARSON	APPROVED	competition pool
Notes: CHLORINE 4.0;; ph 7.2						
	8/10/2011	8/10/2011	CH - POOL	LAURIE PEARSON	APPROVED	instruction pool inside
Notes: CHLORINE 1.5; PH 7.0 (A BIT LOW ON BOTH)						
	8/10/2011	8/10/2011	CH - POOL	LAURIE PEARSON	APPROVED	river pool outside
Notes: CHLORINE 3.0 PH 7.4						
	8/10/2011	8/10/2011	CH - POOL	LAURIE PEARSON	APPROVED	Catch basin below slides
Notes: CHLROINE 2.0; PH 7.0 (A BIT LOW)						
	8/10/2011	8/10/2011	CH - POOL	LAURIE PEARSON	APPROVED	baby pool
Notes: CHLORINE 1.5; PH 7.4 (INCREASE CHLORINE LEVEL A BIT FOR THIS POOL)						
	5/16/2012	8:00 AM 5/16/2012	CH - POOL	JACKIE WELDON	APPROVED	LEISURE POOL
Notes: CHLORINE: 1.4 PH: 7.2						
	5/16/2012	5/16/2012	CH - POOL	JACKIE WELDON	APPROVED	COMPETITIVE POOL
Notes: CHLORINE 1.5 PH: 7.2 POOL WATER WAS CLEAN AND LIFEGUARDS ON DUTY.						
	5/17/2012	1:30 PM 5/17/2012	CH - POOL	JACKIE WELDON	APPROVED	RIVER
Notes: CHLORINE: 2.88 PH: 7.3 VERY CLEAR WATER.						
	5/17/2012	5/17/2012	CH - POOL	JACKIE WELDON	APPROVED	CHILDREN'S SPLASH PAD
Notes: CHLORINE: 2.2 PH: 7.25						

Permit Inspections

City of Denton

	5/17/2012	5/17/2012	CH - POOL	JACKIE WELDON	APPROVED	SLIDE
--	-----------	-----------	-----------	---------------	----------	-------

Notes:

CHLORINE: 4.3 PH: 7.8

OPENING FRIDAY.

	7/13/2012	7/13/2012	CH - POOL	GARY CHAMBERS	APPROVED	OUTSIDE RIVER POOL
--	-----------	-----------	-----------	---------------	----------	--------------------

Notes:

CL -
FREE - 2.25
COMBINED 0.06

CNA - 79

(7/16/2012 2:13 PM GKC)
PH- 8.03

	7/13/2012	7/13/2012	CH - POOL	GARY CHAMBERS	FAILED	SLIDE POOL
--	-----------	-----------	-----------	---------------	--------	------------

Notes:

CL-
FREE- .16
COMBINED - LESS THAN 1

PH LESS THAN 6.5

	7/13/2012	7/13/2012	CH - POOL	GARY CHAMBERS	FAILED	CHILD'S SPLASH PAD
--	-----------	-----------	-----------	---------------	--------	--------------------

Notes:

CL-
FREE - .53
COMBINED - .13
PH- 7.43

	7/13/2012	7/13/2012	CH - POOL	LAURIE PEARSON	APPROVED	Competition pool
--	-----------	-----------	-----------	----------------	----------	------------------

Notes:

Free Chlorine: 2.55
Total Chlorine: 3.56
pH: 7.8
CNA <2

Permit Inspections

City of Denton

	7/13/2012	7/13/2012	CH - POOL	LAURIE PEARSON	APPROVED	Leisure pool
--	-----------	-----------	-----------	----------------	----------	--------------

Notes:

Free Chlorine: 2.58
 Total Chlorine: 3.56
 pH: 7.7

Note: bottom of this pool wearing thin in some parts-- should be re-plastered before next summer (2013)

	8/3/2012	8/3/2012	CH - POOL	LAURIE PEARSON	APPROVED	COMPETITION POOL
--	----------	----------	-----------	----------------	----------	------------------

Notes:

CHLORINE 3.09; PH 7.21; CYANURIC ACID 63

	8/3/2012	8/3/2012	CH - POOL	LAURIE PEARSON	APPROVED	LEISURE POOL
--	----------	----------	-----------	----------------	----------	--------------

Notes:

CHLORINE 4.1; PH 8.02 (A BIT HIGH); CYA 77
 NOTE: BOTTOM OF LEISURE POOL IS PITTED IN SOME AREAS AND NEEDS TO BE PATCHED ETC RESURFACED BEFORE JAN. 31, 2013

	8/3/2012	8/3/2012	CH - POOL	GARY CHAMBERS	APPROVED	CHILD'S SPLASH PAD
--	----------	----------	-----------	---------------	----------	--------------------

Notes:

CL -1.45
 PH - 7.73
 CNA - 30

	8/3/2012	8/3/2012	CH - POOL	GARY CHAMBERS	APPROVED	OUTSIDE RIVER POOL
--	----------	----------	-----------	---------------	----------	--------------------

Notes:

CL:
 FREE - 2.28
 PH - 7.38
 CNA - 30

	8/3/2012	8/3/2012	CH - POOL	GARY CHAMBERS	APPROVED	OUTSIDE SLIDE POOL
--	----------	----------	-----------	---------------	----------	--------------------

Notes:

CL:
 FREE - 1.21
 PH - 7.85
 CNA - 34

Permit Inspections

City of Denton

	1/30/2013	1/30/2013	CH - POOL	JACKIE WELDON	APPROVED	LEISURE POOL
Notes: FREE CHLORINE: 1.77 PPM PH: 7.54						
	1/30/2013	1/30/2013	CH - POOL	JACKIE WELDON	APPROVED	COMPETITION POOL
Notes: FREE: 1.39 PPM PH: 7.34						
	5/15/2013	5/15/2013	CH - POOL	JACKIE WELDON	APPROVED	LAP POOL
Notes: CHLORINE: 1.46 PPM PH: 7.5						
	5/15/2013	5/15/2013	CH - POOL	JACKIE WELDON	APPROVED	LEISURE POOL
Notes: CHLORINE: 2.10 PPM PH: 7.3 PPM						
	5/15/2013	5/15/2013	CH - POOL	JACKIE WELDON	APPROVED	SLIDE POOL
Notes: CHLORINE: 1.14 PPM PH: 6.7						
	5/15/2013	5/15/2013	CH - POOL	JACKIE WELDON	APPROVED	LAZY RIVER
Notes: CHLORINE: 2.81 PPM PH: 8.1 PPM						
	5/15/2013	5/15/2013	CH - POOL	JACKIE WELDON	APPROVED	WADING POOL
Notes: CHLORINE: 8.25 PPM PH: 7.6						
	8/7/2013	8/7/2013	CH - POOL	JACKIE WELDON	APPROVED	SLIDE
Notes: CHLORINE: 1.57 PPM PH: 7.19						
	8/7/2013	8/7/2013	CH - POOL	JACKIE WELDON	APPROVED	LAZY RIVER
Notes: CHLORINE: 3.62 PPM PH: 7.48						

Permit Inspections

City of Denton

	8/7/2013	8/7/2013	CH - POOL	JACKIE WELDON	APPROVED	WADING
Notes:						
CHLORINE: 2.81 PPM						
PH: 7.55						
	8/7/2013	8/7/2013	CH - POOL	JACKIE WELDON	APPROVED	LAP POOL
Notes:						
CHLORINE: 1.26 PPM						
PH: 7.15						
	8/7/2013	8/7/2013	CH - POOL	JACKIE WELDON	APPROVED	LEISURE
Notes:						
CHLORINE: 1.42 PPM						
PH: 7.10						
	1/21/2014	8:00 AM 1/21/2014	CH - POOL	JACKIE WELDON	APPROVED	LEISURE POOL
Notes:						
CHLORINE FREE: 1.81 PPM						
PH: 7.38						
	1/21/2014	1/21/2014	CH - POOL	JACKIE WELDON	APPROVED	COMPETITION POOL
Notes:						
CHLORINE FREE: 1.87 PPM						
PH: 7.53 PPM						
	7/2/2014	7/2/2014	CH - POOL	JACKIE WELDON	APPROVED	NOTES
Notes:						
SLIDE						
CHLORINE 1.65						
PH 6.93						
	7/2/2014	7/2/2014	CH - POOL	JACKIE WELDON	APPROVED	NOTES
Notes:						
LAZY						
2.64						
PH 7.32						
	7/2/2014	7/2/2014	CH - POOL	JACKIE WELDON	APPROVED	NOTES
Notes:						
WADING POOL						
CHLORINE 1.19						
PH 6.83						

Permit Inspections

City of Denton

	7/2/2014	7/2/2014	CH - POOL	JACKIE WELDON	APPROVED	NOTES
Notes: LAP CHLORINE 1.45 PH 7.55						
	7/2/2014	7/2/2014	CH - POOL	JACKIE WELDON	APPROVED	NOTES
Notes: LEISURE 1.45 PH 7.82						
	8/5/2014	8/5/2014	CH - POOL	JACKIE WELDON	APPROVED	Competitive Pool
Notes: Chlorine: 1.58 ppm pH: 7.51 ppm						
	8/5/2014	8/5/2014	CH - POOL	JACKIE WELDON	APPROVED	Leisure Pool
Notes: Chlorine: 1.46 ppm pH: 7.77 ppm						
	8/5/2014	8/5/2014	CH - POOL	JACKIE WELDON	APPROVED	Slide
Notes: Chlorine: 2.15 ppm pH: 7.18						
	8/5/2014	8/5/2014	CH - POOL	JACKIE WELDON	APPROVED	BABY POOL
Notes: Chlorine: 3.43 ppm pH: 7.05						
	8/5/2014	8/5/2014	CH - POOL	JACKIE WELDON	APPROVED	Lazy
Notes: Chlorine: 1.71 ppm pH: 7.34 ppm						
	2/11/2015	9:45 AM 2/11/2015	CH - POOL	JACKIE WELDON	APPROVED	COMPETITION POOL
Notes: CHLORINE: 1.32 ppm pH: 7.55						

Permit Inspections

City of Denton

	2/11/2015	2/11/2015	CH - POOL	JACKIE WELDON	APPROVED	LEISURE POOL	
Notes:							
CHLORINE: 1.78 ppm							
pH: 7.40 ppm							
	5/19/2015	5/19/2015	CH - POOL	SARA LOSH	APPROVED	BABY	
Notes:							
CL-3.85							
PH-6.52							
	5/19/2015	5/19/2015	CH - POOL	SARA LOSH	APPROVED	LAZY RIVER	
Notes:							
CL-0							
PH-7.53							
	5/19/2015	5/19/2015	CH - POOL	SARA LOSH	APPROVED	SLIDE	
Notes:							
CL-6.98							
PH-3.54							
	7/21/2015	8:00 AM	7/21/2015	CH - POOL	JACKIE WELDON	APPROVED	SLIDE
Notes:							
CHLORINE: 3.41							
pH: 7.49							
	7/21/2015	8:00 AM	7/21/2015	CH - POOL	JACKIE WELDON	APPROVED	BABY POOL
Notes:							
CHLORINE: 2.62 ppm							
pH: 7.60 ppm							
	7/21/2015	7/21/2015	CH - POOL	JACKIE WELDON	APPROVED	LAZY RIVER	
Notes:							
CHLORINE: 4.53 ppm							
pH: 7.29 ppm							
	5/17/2016	5/17/2016	CH - POOL	SARA LOSH	APPROVED	BABY	
Notes:							
2.03 CL							
6.8 PH							

Permit Inspections

City of Denton

	5/17/2016	5/17/2016	CH - POOL	SARA LOSH	APPROVED	SLIDE
Notes: 2.22 CL 6.63 PH						
	5/17/2016	5/17/2016	CH - POOL	SARA LOSH	APPROVED	LAZY RIVER
Notes: 2.63 CL 6.81 PH						
	5/17/2016	5/17/2016	CH - POOL	SARA LOSH	APPROVED	LEISURE
Notes: 2.23 CL 7.67 PH						
	5/17/2016	5/17/2016	CH - POOL	SARA LOSH	APPROVED	COMPETITION
Notes: 2.16 CL 6.94 PH						
	5/18/2017	8:30 AM 5/18/2017	CH - POOL	GARY CHAMBERS	APP W/COND	COMP POOL
Notes: CL - 1.78 PH-7.17 CYA - 0 REPLACE MIISING & DAMAGED TILE ALONG EDGES.						
	5/18/2017	5/18/2017	CH - POOL	GARY CHAMBERS	APPROVED	LEISURE POOL
Notes: CL- 2.26 PH-7.52 CYA -2						
	5/18/2017	5/18/2017	CH - POOL	GARY CHAMBERS	FAILED/INCOM PLETE	WADING POOL - CLOSED AT TIME OF INSPECTI
Notes: CL - .11 PH <6.5 CYA- 5						

Permit Inspections

City of Denton

	5/18/2017	5/18/2017	CH - POOL	GARY CHAMBERS	APPROVED	WINDING RIVER POOL
--	-----------	-----------	-----------	---------------	----------	--------------------

Notes:

CL - 2.14

PH- 7.83

CYA <2

	5/18/2017	5/18/2017	CH - POOL	GARY CHAMBERS	APPROVED	SLIDE POOL
--	-----------	-----------	-----------	---------------	----------	------------

Notes:

CL - 2.01

PH- 7.62

CYA- <2

	7/25/2017	7/25/2017	CH - POOL	GARY CHAMBERS	APPROVED	INDOOR DIVING POOL
--	-----------	-----------	-----------	---------------	----------	--------------------

Notes:

CL - 1.02

PH - 7.44

CYA-3

	7/25/2017	7/25/2017	CH - POOL	GARY CHAMBERS	APPROVED	INDOOR SLIDE POOL
--	-----------	-----------	-----------	---------------	----------	-------------------

Notes:

CL - 1.8

PH - 7.21

CYA - <2

	7/25/2017	7/25/2017	CH - POOL	GARY CHAMBERS	APPROVED	OUTDOOR SLIDE POOL
--	-----------	-----------	-----------	---------------	----------	--------------------

Notes:

CL - 1.25

PH - 7.37

CYA - 5

Permit Inspections

City of Denton

	7/25/2017	7/25/2017	CH - POOL	GARY CHAMBERS	APPROVED	RIVER
Notes: CL -1.65 PH - 7.16 CYA- 4						
	7/25/2017	7/25/2017	CH - POOL	GARY CHAMBERS	APPROVED	WATER FEATURE POOL
Notes: CL - 1.43 PH - 7.52 CYA- 3						
	7/25/2017	7/25/2017	CH - POOL	GARY CHAMBERS	APPROVED	WAVE POOL
Notes: CL - 1.01 PH - 7.38 CYA-3						
	1/29/2018	1/29/2018	CH - COMPLAINT	SARA LOSH	CHECK NOTES	CHECK NOTES
Notes: RECEIVED COMPLAINT OF ELECTRICAL CORDS NEAR WATER DURING A MEET						
	1/29/2018	1/29/2018	CH-FOLLOW-UP	SARA LOSH	CHECK NOTES	CHECK NOTES
Notes: SPOKE WITH CATHY AVERY AND THE DISD REP FOR THE MEETS, BILLY EWTON TO DO SITE VISIT						
	5/29/2018	5/29/2018	CH - POOL	JACKIE ACOSTA	APPROVED	SLIDE POOL
Notes: CHLORINE 1.60 PPM pH: 6.59 ppm *Low. It was increased while there						
	5/29/2018	5/29/2018	CH - POOL	JACKIE ACOSTA	APPROVED	WAVE POOL
Notes: CHLORINE: 4.42 PPM pH: 7.63 ppm						
	5/29/2018	5/29/2018	CH - POOL	JACKIE ACOSTA	APPROVED	KIDDIE POOL
Notes: Chlorine: 2.28 ppm pH: 7.26 ppm						

Permit Inspections

City of Denton

	5/29/2018	5/29/2018	CH - POOL	JACKIE ACOSTA	APPROVED	LAZY RIVER
Notes: CHLORINE: 4.39 ppm pH: 7.26 ppm						
	5/29/2018	5/29/2018	CH - POOL	JACKIE ACOSTA	APPROVED	Leisure Pool
Notes: Chlorine: 2.9 ppm pH: 7.36 ppm						
	5/29/2018	5/29/2018	CH - POOL	JACKIE ACOSTA	APPROVED	COMPETITIVE POOL
Notes: Chlorine: 2.08 ppm pH: 7.23 ppm						
	8/9/2018	9:30 AM 8/9/2018	CH - POOL	JACKIE ACOSTA	FAILED	SPLASH PAD
Notes: CHLORINE: 0 ppm *Tom K added chlorine to pool. Will contact me with new readings. pH: 6.97 ppm * low, will contact me with new readings						
	8/9/2018	8/9/2018	CH - POOL	JACKIE ACOSTA	APPROVED	LAZY RIVER
Notes: CHLORINE: 3.07 ppm pH: 7.62 ppm						
	8/9/2018	8/9/2018	CH - POOL	JACKIE ACOSTA	APPROVED	SLIDE POOL
Notes: CHLORINE: 2.63 ppm pH: 7.29 ppm						
	8/9/2018	8/9/2018	CH - POOL	JACKIE ACOSTA	APPROVED	WAVE POOL
Notes: CHLORINE: 2.57 ppm pH: 7.39 ppm						
	8/9/2018	8/9/2018	CH - POOL	JACKIE ACOSTA	APPROVED	COMPETITION POOL
Notes: CHLORINE: 3.3 ppm pH: 7.85 ppm						

Permit Inspections

City of Denton

	8/9/2018	8/9/2018	CH - POOL	JACKIE ACOSTA	APPROVED	LEISURE POOL
--	----------	----------	-----------	---------------	----------	--------------

Notes:

CHLORINE: 2.5 ppm

pH: 7.5 ppm

	8/9/2018	10:30 AM	8/9/2018	CH - POOL	JACKIE ACOSTA	APPROVED	SPLASH PAD
--	----------	----------	----------	-----------	---------------	----------	------------

Notes:

CHLORINE: 2.80 ppm

pH: 7.65 ppm

Good to go.

	6/17/2019	6/17/2019	CH - POOL	JACKIE ACOSTA	APPROVED	COMPETITIVE POOL
--	-----------	-----------	-----------	---------------	----------	------------------

Notes:

CHLORINE: 2.79 ppm

pH: 7.49 ppm

	6/17/2019	6/17/2019	CH - POOL	JACKIE ACOSTA	APPROVED	LEISURE POOL
--	-----------	-----------	-----------	---------------	----------	--------------

Notes:

CHLORINE: 1.53 ppm

pH: 7.34 ppm

	6/17/2019	6/17/2019	CH - POOL	JACKIE ACOSTA	APPROVED	WAVE POOL
--	-----------	-----------	-----------	---------------	----------	-----------

Notes:

CHLORINE: 2.11 ppm

pH: 6.75 ppm * Too low. Add some sodium ash and call me with new readings.

	6/17/2019	6/17/2019	CH - POOL	JACKIE ACOSTA	APPROVED	SLIDE POOL
--	-----------	-----------	-----------	---------------	----------	------------

Notes:

pH: 7.52 ppm

CHLORINE: 2.24 ppm

	6/17/2019	6/17/2019	CH - POOL	JACKIE ACOSTA	APPROVED	LAZY RIVER
--	-----------	-----------	-----------	---------------	----------	------------

Notes:

CHLORINE: 2.30 ppm

pH: 7.42 ppm

Permit Inspections

City of Denton

	6/17/2019	6/17/2019	CH - POOL	JACKIE ACOSTA	APPROVED	SPLASH PAD
Notes:						
Chlorine: 3.11 ppm						
pH: 7.29 ppm						
	6/17/2019	6/17/2019	CH - POOL	JACKIE ACOSTA	APPROVED	WAVE POOL
Notes:						
pH: 7.4 ppm before it open at 11:00						
	8/28/2019	8/28/2019	CH - POOL	JESSICA GRIFFITH	APPROVED	COMPETITIVE POOL
Notes:						
CL: 2.02						
PH: 7.60						
	8/28/2019	8/28/2019	CH - POOL	JESSICA GRIFFITH	APPROVED	LEISURE POOL
Notes:						
CL: 1.94						
PH: 7.60						
	7/23/2020	7/23/2020	CH - POOL	KEVIN CUMMINGS	CHECK NOTES	Pool Closed - COVID
Notes:						
Pool Closed - COVID						
	5/26/2021	9:00 AM 5/26/2021	CH - POOL	JACKIE ACOSTA	APPROVED	COMPETITIVE POOL
Notes:						
CHLORINE: 1.66 ppm						
pH: 7.45 ppm						
	5/26/2021	5/26/2021	CH - POOL	JACKIE ACOSTA	APPROVED	LEISURE POOL
Notes:						
CHLORINE: 3.0 PPM						
pH: 7.60 ppm						
	5/26/2021	5/26/2021	CH - POOL	JACKIE ACOSTA	APPROVED	SLIDE POOL
Notes:						
CHLORINE: 4.11 ppm						
pH: 7.78 ppm						

Permit Inspections

City of Denton

	5/26/2021	5/26/2021	CH - POOL	JACKIE ACOSTA	APPROVED	LAZY RIVER POOL
Notes: Chlorine: 1 ppm pH: 7.95 ppm						
	5/26/2021	5/26/2021	CH - POOL	JACKIE ACOSTA	APPROVED	WAVE POOL
Notes: CHLORINE: 3.17 ppm pH: 7.81 ppm						
	5/26/2021	5/26/2021	CH - POOL	JACKIE ACOSTA	APPROVED	KIDDIE SPLASH AREA
Notes: CHLORINE 1.0 pH: 7.0						
	7/22/2021	8:30 AM 7/22/2021	CH - POOL	JACKIE ACOSTA	APPROVED	SLIDE
Notes: CHLORINE: 3.14 ppm pH: 7.8 ppm						
	7/22/2021	7/22/2021	CH - POOL	JACKIE ACOSTA	APPROVED	LAZY RIVER
Notes: CHLORINE: 2.5 ppm pH: 7.34 ppm						
	7/22/2021	7/22/2021	CH - POOL	JACKIE ACOSTA	APPROVED	LAP POOL INSIDE
Notes: CHLORINE: 2.68 PPM pH: 7.2 ppm						
	7/22/2021	7/22/2021	CH - POOL	JACKIE ACOSTA	APPROVED	LEISURE POOL
Notes: CHLORINE: 2.5 ppm pH: 7.39 ppm						
	7/22/2021	7/22/2021	CH - POOL	JACKIE ACOSTA	APPROVED	SPLASH PAD
Notes: CHLORINE: 3.08 ppm pH: 7.2 ppm						
	7/22/2021	7/22/2021	CH - POOL	JACKIE ACOSTA	APPROVED	WAVE POOL
Notes: CHLORINE: 3.0 ppm pH: 7.63 ppm						

Permit Inspections

City of Denton

	7/30/2021	4:00 PM	7/30/2021	4:30 PM	CH - COMPLAINT	KEVIN CUMMINGS	CHECK NOTES	Indoor Pools complaint
--	-----------	------------	-----------	------------	----------------	-------------------	-------------	------------------------

Notes:
FD called to pools due to "Chlorine Smell" causing irritation to the swimmers / water polo players. FD did not get any results on air analyzer. Upon my arrival, FD had evacuated the area, was venting the swimmer area with fans, and had Facilities en-route with 4 ft box fans. I noted a slight odor of chloramines, but no one in the facility at that time seemed affected by the levels. I told FD they could let the swimmers back in after the box fans were installed.